

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499


TEST REPORT

Client :	Davcor 14 John Hines Avenue	Test Number Issue Date	:	17-005932 15/11/2017
	Minchinbury NSW 2770	Print Date	:	17/11/2017

Sample Description	Clients Ref :	"CVL Window lock"
	Window lock	

Compression Testing

Specimen	Load to Failure (N)		
1	1426		
2	1161		
3	1313		
Mean	1300		
Force Applied to:	The lock body		
Type of Failure Observed:	Failure of the locking pin		
Equipment:	CRE Instron, Model 4206		
Load Cell Capacity:	10kN		
Crosshead Speed Used:	100mm/min		






Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Davcor 14 John Hines Avenue Minchinbury NSW 2770

Test Number	:	17-005932
Issue Date	:	15/11/2017
Print Date	:	17/11/2017





APPROVED SIGNATORY




Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106 1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Davcor 14 John Hines Avenue Minchinbury NSW 2770

Test Number	:	17-005932
Issue Date	:	15/11/2017
Print Date	:	17/11/2017





MICHAEL A. JACKSON B.Sc.(Hons)